







Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
1	15 mm	Make:Globtech, Model: GTL-UM, Type: Ultrasonic DN15, Q3: 2.5 m3/h, R400, T50, Δp63, MAP16, Class 2	ISO 4064: 2024	M/s. Global Trade Links #613,4TH Main ,9TH BL,Nagarabhavi, Bangalore.	30-Jan-26	
2	15 mm	Make: Globtech, Size: DN15, Qn 1.5 m3/h, Class B, Type: Multijet Inferential.	ISO 4064-1: 1993	M/s. Global Trade Links #613,4TH Main ,9TH BL,Nagarabhavi, Bangalore.	14-Jan-26	
3	15 mm	Make: Kranti, Model: Peyjal Smart, Type: Ultrasonic DN15, Q3: 1.6 m3/h, R40, T50, Δp63, MAP16, Class 2	ISO 4064: 2024	M/s. Aman Engineering Works C 54/55 Focal Point Extension Jalandhar	02-Dec-25	
4	15 mm	Make: Kranti - Ultra-G, Size: DN15, Qn 1.5 m3/h, Class B, Type: Multijet "With Copper Can Register".	IS 779: 1994	M/s. Aman Engineering Works C 54/55 Focal Point Extension Jalandhar	02-Dec-25	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcricindia.com





E-mail : cwm@fcricindia.com, customercare@fcricindia.com

Page 1 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
5	15mm	Make: Ripple, Model: RLW Type: Ultrasonic DN15, Q3: 2.5 m ³ /h, R400, T50, Δp63, MAP16, Class 2, (with metal flow tube)	ISO 4064: 2024	M/s. Ripple Smart Metering Limited. Plot. No.52, 1st Floor, Lingiah Nagar, Balkampet, Hyderabad- 500018	13-Oct-25	
6	15mm	Make: Ripple, Model: RLW Type: Ultrasonic DN15, Q3: 2.5 m ³ /h, R400, T50, Δp63, MAP16, Class 2, (with plastic flow tube)	ISO 4064: 2024	M/s. Ripple Smart Metering Limited. Plot. No.52, 1st Floor, Lingiah Nagar, Balkampet, Hyderabad- 500018	13-Oct-25	
7	15 mm	Make: Spire Metering Technology LLC, Model: 280W- R-NV(wPrime) Type: Ultrasonic Q3: 2.5 m ³ /h, R250, T50, Δp63, MAP16, Class 2	ISO 4064: 2014	M/s. Technochem Agencies(Bombay) Pvt Ltd. 31-A,Giriraj Industrial Estate,Mahakali Caves Road,Andheri(East),Mumbai- 400093.	10-Oct-25	
8	15 mm	Make: Konarak, Model: KMJ- 15 Copper Can, Type: Multijet. DN15, Q3: 2.5 m ³ /h, R100, T50, Δp63, MAP16, Class 2	ISO 4064: 2014	M/s. Venus Industries # 4, Devayani Industrial Complex. Subramanyapura Post, Uttrahalli main Road , Gowdanpalya, Banagalore-560061.	29-Sep-25	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcricindia.com





E-mail : cwm@fcricindia.com, customercare@fcricindia.com

Page 2 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)





Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
9	15 mm	Make: Aqua, Size: DN15, Qn 1.5 m ³ /h, Class B, Type: Multijet Inferential.	IS 779: 1994	M/s. Automat Industries Private Limited, B-12B-12/1, 12/2, site-IV, Govind Ballabh Pant Marg, Sahibabad Industrial Area, UP-201010.	21-Jul-25	
10	15 mm	Make: Rahul, Size: DN15, Qn 1.5 m ³ /h, Class B, Type: Multijet Inferential.	IS 779: 1994	M/s. Rajasthan Industrial Scientific Corp (JP), 39-40 Industrial Area, Jhotwara - 302012.	21-Jul-25	
11	15 mm	Make: Jal Jeevan, Size: DN15, Qn 1.5 m ³ /h, Class B, Type: Multijet Inferential.	IS 779: 1994	M/s. Venus Industries, NO.4, Devayani Industrial Complex, Subramanyapura Main Road, Gowdanpalaya, Bangalore - 560061.	21-Jul-25	
12	15 mm	Make: Axioma, Model: QalcosonicW1, Type: Ultrasonic, Q3: 10 m ³ /h, R400, T50, Δp25, MAP16, Class 2	ISO 4064: 2014	M/s. Livefibre Connect Pvt Ltd , Plot No. 409, Udyog Kendra-2, Ecotech-3, Uttar Pradesh.	17-Jul-25	



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
13	15 mm	Make: Ideal, Type: Ultrasonic, Q3: 2.5 m ³ /h, R400, T50, Δp63, MAP16, Class 2	ISO 4064: 2014	M/s. Nixies Meters Pvt. Ltd. #320, Epip Indl. Layout, Ganjimutt, Mangalore.	11-Jul-25	
14	15 mm	Make : Belanto, Type: Multijet Class B	IS 779: 1994	M/s B.M. Water Meters, Village Salempur Musalmana Jalandhar, Punjab 144004 FUTURE@BMWATERMETERS.COM	24-Jun-25	
15	15 mm	Make: Eureka , Model: EUAMR, Type: Ultrasonic Q3: 2.5 m ³ /h, R250, T30, Δp25, MAP16, Class2	ISO 4064: 2014	M/s. Eureka Industrial Equipment Pvt Ltd. J-501 Block, MIDC Area, PIMPRI, Pune.	30-Apr-25	
16	15 mm	Make: Capital, Model: GILA, Type: Ultrasonic Q3: 2.5 m ³ /h, R400, T50, Δp63, MAP16, Class2	ISO 4064: 2014	M/s. Capital Power System Ltd., B-40, Scetor-4, Noida Dist, Buddha Nagar, UP.	21-Apr-25	

Centre for Water Management, Fluid Control Research Institute, Kanjikkode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcricindia.com





E-mail : cwm@fcricindia.com, customercare@fcricindia.com

Page 4 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
17	15 mm	Make: Gold, Model: GWM-UM, Type: Ultrasonic Q3: 2.5 m ³ /h, R400, T50, Δp63, MAP16, Class2	ISO 4064: 2014	M/s Gold Water Meter (India) Ptd Ltd., Plot No. F443 C, Road No. 12, Vishwakarma Industrial Area, Jaipur, Rajasthan.	10-Mar-25	
18	15 mm	Make: Konarak, Type: Ultrasonic DN 15, Q3: 2.5 m ³ /h, R250, T30, Δp63, MAP16, Class 2	ISO 4064: 2014	M/s Venus Industries, No. 4 Devayani Industrial Complex, Gowdana Palaya, Bangalore 560 061 www.konarakmeters.com venusmeters@gmail.com	17-Feb-25	
19	15 mm	Make: Sensus - IPERL Type: Electromagnetic DN 15, Q3: 2.5 m ³ /h, R800, T50, Δp40, MAP16, Class 2	ISO 4064: 2014	Xylem Water Solutions India Pvt. Ltd. 5th Floor, B Wing, Lodha I-Think Techno Campus, Off Eastern Express Highway, Thane (W), Maharashtra - 400601. Email: deepak.naik@xylem.com	15-Jan-25	
20	15 mm	Make : Konarak, Type: Multijet Class B	IS 779: 1994	M/s Venus Industries, No. 4 Devayani Industrial Complex, Gowdana Palaya, Bangalore 560 061 www.konarakmeters.com venusmeters@gmail.com	20-Sep-24	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcricindia.com





E-mail : cwm@fcricindia.com, customercare@fcricindia.com

Page 5 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
21	15 mm	Make : Konarak, Type: Multijet Class B	IS 779: 1994	M/s Venus Industries, No. 4 Devayani Industrial Complex, Gowdana Palaya, Bangalore 560 061 www.konarakmeters.com venusmeters@gmail.com	30-Aug-24	
22	15 mm	Make: Glycon, Type: Multijet, Class B.	IS 779: 1994	M/s. Kaizen Polymers, 1/323. M.G. Kavu, P.O Thangaloor, Kerala. Email: technicalresources1973@gmail.com	31-Aug-24	
23	15 mm	Make: Sensus, Model: 420+, Type: Multijet, Q3: 2.5 m ³ /h, R160, T50, Δp63, MAP16, Class 2	ISO 4064: 2014	Xylem Water Solutions India Pvt. Ltd., 5th Floor, B Wing, Lodha I-Think Techno Campus, Off Eastern Express Highway, Thane West, Maharashtra. www.xylem.com, www.Sensus.com	23-Jul-24	
24	15 mm	Make: SBEM, Model: Aqua Sonic , Model: 153 RWM, DN15, Q3: 2.5 m ³ /h, R400, T50, Δp 16, MAP16, Class 2	ISO 4064: 2014	M/s SBEM Pvt. Ltd, Gauddara Road, Khed Shivapur, Pune – 412 205 www.sbem-india.com	18-Jun-24	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcricindia.com





E-mail : cwm@fcricindia.com, customercare@fcricindia.com

Page 6 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)




Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
25	15 mm	Make: Kamstrup Model: Flow IQ 2101DN15, Q3: 2.5 m ³ /h, R250, T50, Δp63, MAP16, Class 2	ISO 4064: 2014	M/s Kamstrup Metering Solutions Pvt Ltd.210, 2nd floor, Lodha Supremus 1,Road No22, Wagle Industrial Estate, Thane, Maharashtra 400604 www.kamstrup.com	30-Apr-24	
26	15 mm	Make: ToshinType: Multijet Q3: 2.5 m ³ /h, R100,T30, Δp63,MAP16, Class 2	ISO 4064: 2014	M/s. Yong India Pvt Ltd, Mangalam Lane-1, Sasthamangalam, Trivandrum 695010.	20-Dec-23	
27	15 mm	Make: Axioma, Model:QALCOSONIC W1, Type: Ultrasonic Q3: 1.6 m ³ /h, R400, T50, Δp16, MAP16, Class 2	ISO 4064: 2014	M/s LiveFibre Connect Pvt Ltd, Plot No. 409, Udyog Kendra, Ecotech III, Uttar Pradesh - 201306.	14-Dec-23	
28	15 mm	Make: Baylan, Model: TK-12 Type: Multijet, Class B.	IS 779: 1994	M/s Aquameas Instruments Pvt Ltd, Shivkamal Industrial Estate, Shivane, Pune 411016 Maharashtra, www.aquameas.com sales@aquameas.com	04-Dec-23	



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
29	15 mm	Make: Fedrel, Type: Multijet, Class B	IS 779: 1994	M/s. V A Valves Pvt Ltd, Udyog Nagar, Gadaipur P O, Jalandhar, Punjab -144004.	03-May-23	
30	15 mm	Make: GKM, Type: Multijet, Class B	IS 779: 1994	M/s. Guru Kripa Metal ,.# C-26, Focal Point, Chanalon , Punjab, 140103	12-Jul-23	
31	20mm	Make: Ripple, Model: RLW Type: Ultrasonic DN20, Q3: 4.0 m3/h, R400, T50, Δp63, MAP16, Class 2 (with metal flow tube)	ISO 4064: 2024	M/s. Ripple Smart Metering Limited. Plot. No.52, 1st Floor, Lingiah Nagar, Balkampet, Hyderabad- 500018	13-Oct-25	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcriindia.com





E-mail : cwm@fcriindia.com, customercare@fcriindia.com

Page 8 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
32	20mm	Make: Ripple, Model: RLW Type: Ultrasonic DN20, Q3: 4.0 m3/h, R400, T50, Δp63, MAP16, Class 2 (with plastic flow tube)	ISO 4064: 2024	M/s. Ripple Smart Metering Limited. Plot. No.52, 1st Floor, Lingiah Nagar, Balkampet, Hyderabad- 500018	13-Oct-25	
33	20 mm	Make: Nudron, Model: NUFM-B-20W, Type: Ultrasonic Q3: 4.0 m3/h, R400, T50, Δp63, MAP16, Class2	ISO 4064: 2014	M/s. Nudron IOT Solutions LLP,. #10 Gitaneel Arcade, Hill Road, Bandra-West, Mumbai.	27-May-25	
34	20 mm	Make: Viondot, Model: VSM-UFM-1000, Type: Ultrasonic Q3: 4.0 m3/h, R400, T50, Δp63, MAP16, Class2	ISO 4064: 2014	M/s.Viondot Smart Services Pvt Ltd, GF, D-171 , Sector 63, Noida, Uttar Pradesh.	17-Apr-25	
35	20 mm	Make: Capital, Model: GILA, Type: Ultrasonic Q3: 4.0 m3/h, R400, T50, Δp63, MAP16, Class2	ISO 4064: 2014	M/s. Capital Power System Ltd,. B-40, Scetor-4, Noida Dist, Buddha Nagar, Uttar Pradesh.	17-Apr-25	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206





Url : www.fcricindia.com

E-mail : cwm@fcricindia.com, customercare@fcricindia.com



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb, 2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
36	20 mm	Make: Sensus - IPERL Type: Electromagnetic DN 20, Q3: 4.0 m ³ /h, R800, T50, Δp40, MAP16, Class 2	ISO 4064: 2014	Xylem Water Solutions India Pvt. Ltd. 5th Floor, B Wing, Lodha I-Think Techno Campus, Off Eastern Express Highway, Thane (W), Maharashtra - 400601. Email: deepak.naik@xylem.com	28-Nov-24	
37	20 mm	Make: Axioma, Model: QALCOSONIC W1, Type: Ultrasonic Q3: 4 m ³ /h, R400, T30, Δp25, MAP16, Class 2	ISO 4064: 2014	M/s LiveFibre Connect Pvt Ltd, Plot No. 409, Udyog Kendra, Ecotech III, Uttar Pradesh - 201306.	09-Jul-24	
38	20 mm	Make: Kamstrup Model: Flow IQ 2101DN20, Q3: 2.5 m ³ /h, R250, T50, Δp 63 bar, MAP16, Class 2	ISO 4064: 2014	M/s Kamstrup Metering Solutions Pvt Ltd. 210, 2nd floor, Lodha Supremus 1, Road No22, Wagle Industrial Estate, Thane, Maharashtra 400604 www.kamstrup.com	09-Mar-24	
39	25 mm	Make: Ideal, Model: NX-UWM, Type: Ultrasonic Q3: 6.3 m ³ /h, R400, T50, Δp63, MAP16, Class 2	ISO 4064: 2014	M/s. Nixies Meters Private Limited., Plot No.32, EPIP, Industrial Layout, Ganjimmutt, Mangalore.	03-Nov-25	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcricindia.com




E-mail : cwm@fcricindia.com, customercare@fcricindia.com

Page 10 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)




Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
40	25 mm	Make: Sensus - IPERL Type: Electromagnetic DN25, Q3: 6.3 m ³ /h, R800, T50, Δp40, MAP16, Class 2	ISO 4064: 2014	Xylem Water Solutions India Pvt. Ltd. 5th Floor, B Wing, Lodha I-Think Techno Campus, Off Eastern Express Highway, Thane (W), Maharashtra - 400601. Email: deepak.naik@xylem.com	28-Nov-24	
41	25 mm	Make: Kritisnam, Model:Dhaara Smart, Type: Ultrasonic, Q3: 6.3 m ³ /h, R40, T50, Δp63, MAP16, Class 2	ISO 4064: 2014	M/s. Kritisnam Technologies Pvt. Ltd., Plot No. 347, Rd number 22, Jubilee Hills, Hyderabad, Telangana - 500033. www.kritisnam.com	09-Jul-24	
42	25 mm	Make: Axioma, Model:QALCOSONIC W1, Type: Ultrasonic Q3: 6.3 m ³ /h, R400, T50, Δp25, MAP16, Class 2	ISO 4064: 2014	M/s LiveFibre Connect Pvt Ltd, Plot No. 409, Udyog Kendra, Ecotech III, Uttar Pradesh - 201306.	23-Jul-24	



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
43	25 mm	Make: SBEM AquaSonic, Model: 153 RWMT Type: Ultrasonic Q3: 6.3 m ³ /h, R400, T50, Δp 16 bar, MAP16, Class 2	ISO 4064: 2014	M/s SBEM Pvt. Ltd, Gaud dara Road, Khed Shivapur, Pune – 412 205. www.sbem-india.com	13-Jan-24	
44	32 mm	Make: Axioma, Model: QalcosonicW1, Type: Ultrasonic, Q3: 10 m ³ /h, R400, T50, Δp25, MAP16, Class 2	ISO 4064: 2014	M/s. Livefibre Connect Pvt Ltd , Plot No. 409, Udyog Kendra-2, Ecotech-3, Uttar Pradesh.	17-Jul-25	
45	40 mm	Make: Sensus, Model: IPERL, Type: Electromagnetic DN40, Q3: 16 m ³ /h, R800, T50, Δp40, MAP16, Class 2	ISO 4064: 2024	M/s Xylem Water Solutions India Pvt. Ltd. 5th Floor, B Wing, Lodha I-Think Techno Campus, Off Eastern Express Highway, Thane –West, MH- 400601	12-Jan-26	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcricriindia.com




E-mail : cwm@fcricriindia.com, customercare@fcricriindia.com




Page 12 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026





Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
46	40 mm	Make: Spire Metering Technology LLC, Model: 280W-R-NV(wPrime) Type: Ultrasonic Q3: 16 m ³ /h, R250, T50, Δp63, MAP16, Class 2	ISO 4064: 2024	M/s. Technochem Agencies(Bombay) Pvt Ltd. 31-A,Giriraj Industrial Estate,Mahakali Caves Road,Andheri(East),Mumbai-400093.	15-Sep-25	
47	40 mm	Make: Axioma, Model: QalcosonicW1, Type: Ultrasonic, Q3: 25 m ³ /h, R250, T50, Δp25, MAP16, Class 2	ISO 4064: 2014	M/s. Livefibre Connect Pvt Ltd , Plot No. 409, Udyog Kendra-2, Ecotech-3, Uttar Pradesh.	24-Jul-25	
48	50 mm	Make: Aqua Meter, Size: DN50, Qn 15 m ³ /h, Class B, Type: Woltman.	ISO 4064 - 1: 1993	M/s Automat Industries Private Limited, B-12/1, B-12/2, Site IV, Govind Ballab Pant Marg, Sahibabad Industrial Area, Ghaziabad.	05-Feb-26	

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
49	50 mm	Make: Spire Metering Technology LLC, Model: 280W-CI2(wPrime), Q3: 25 m ³ /h, R250, T50, Δp63, MAP16, Class 2	ISO 4064: 2014	M/s. Technochem Agencies(Bombay) Pvt Ltd. 31-A,Giriraj Industrial Estate,Mahakali Caves Road,Andheri(East),Mumbai-400093.	30-Sep-25	
50	50 mm	Make: Kamstrup Model: Flow IQDN50, Q3: 25 m ³ /h, R160, T50, Δp 0.16 bar, MAP16, Class 2	ISO 4064: 2014	Kamstrup Metering Solutions Pvt Ltd., Kapurbawdi, G B Road, Thane (West), Maharashtra. www.kamstrup.com	26-Sep-22	
51	50 mm	Make: Adept -Agua Type: Woltman Class B	ISO 4064: 1993	M/s. Adept Fluidraulics Private Ltd, 33A, Nehru Street, Civil Aerodrome (PO), Coimbatore.	12-Sep-22	



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
52	50 mm	Make: Kranti, Type: Woltman Class B	ISO 4064: 1993	M/s Aman Engineering Works C 54/55 Focal Point Extension Jalandhar, Punjab. Email: krantimeters@gmail.com, www.kranti-group.com	14-Jun-22	
53	50 mm	Make : Sensus – WPD Type: WoltmanQ3: 25 m3/h, R63, T50, Δp 40, MAP16, Class 2	ISO 4064:2014	Xylem Water Solutions India Private Limited Coral Square, 7th Floor, Near Suraj Water Park, Vijay Garden Naka, Ghodbunder Road, Thane, Maharashtra, www.Xylem.com, www.Sensus.com, Email: Deepak.Naik@xylem.com	23-May-22	
54	65 mm	Make : Kamstrup, Model: flowIQ 3100, Type: Ultrasonic Q3:40m3/h, R160, T50, Δp 63, Class 2	ISO 4064: 2014	M/s Kamstrup Metering Solutions Pvt.Ltd, 214, Orion Business park, Kapurbawadi, Thane (West) – 400610. www.kamstrup.com	26-Sep-22	
55	80 mm	Make: Aqua Meter, Size: DN80, Qn 40 m3/h, Class B, Type: Woltman.	ISO 4064-1:1993	M/s Automat Industries Private Limited, B-12/1, B-12/2, Site IV, Govind Ballab Pant Marg, Sahibabad Industrial Area, Ghaziabad.	05-Feb-26	

Centre for Water Management, Fluid Control Research Institute, Kanjikode West, Palakkad – 678623

Phone – 91-491-2566120 / 2566206

Url : www.fcricindia.com


E-mail : cwm@fcricindia.com, customercare@fcricindia.com

Page 15 of 16 Pages



Water Meters qualified in FCRI Model Approval Program (MAP)

Dated: 10th Feb,
2026

Sl. no.	Size	Description of the Meter	Standards Referred	Manufacturer / Supplier	Date of Issue of Certificate	Sample tested
56	80 mm	Make : Kamstrup, Model: flowIQ 3100, Type: Ultrasonic Q3:63m ³ /h, R160, T50, Δp 63, Class 2	ISO 4064: 2014	M/s Kamstrup Metering Solutions Pvt.Ltd, 214, Orion Business park, Kapurbawadi, Thane (West) – 400610. www.kamstrup.com	27-Sep-22	

Note: Buyers are advised to have the meters tested for acceptance during the supply of meters. The acceptance test procedures and acceptance criteria are
Disclaimer : The above list is issued solely to confirm that the models mentioned have passed the endurance test as per the applicable standards. FCRI shall